



## Energy Statement

SHD Residential Development  
Knockrabo Phase 2, Mount Anville Road, Goatstown, Dublin 14.

October 2021

**Waterman Moylan Consulting Engineers Limited**

Block S Eastpoint Business Park, Alfie Byrne Road, Dublin D03 H3F4  
[www.waterman-moylan.ie](http://www.waterman-moylan.ie)





**Client Name:** Knockrabo Investments DAC  
**Document Reference:** 20-086.r008  
**Project Number:** 21-086

## Quality Assurance – Approval Status

This document has been prepared and checked in accordance with  
Waterman Group's IMS (BS EN ISO 9001: 2015, BS EN ISO 14001: 2015)

---

<b>Issue</b>	<b>Date</b>	<b>Prepared by</b>	<b>Checked by</b>	<b>Approved by</b>
1	05-02-2021	Andrew Cruise	Niall Coughlan	Niall Coughlan
2	15-10-2021	Margaret Dolan	Niall Coughlan	Niall Coughlan
3	27-10-2021	Margaret Dolan	Niall Coughlan	Niall Coughlan

## Comments

---

## Disclaimer

This report has been prepared by Waterman Moylan, with all reasonable skill, care and diligence within the terms of the Contract with the Client, incorporation of our General Terms and Condition of Business and taking account of the resources devoted to us by agreement with the Client.

We disclaim any responsibility to the Client and others in respect of any matters outside the scope of the above.

This report is confidential to the Client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at its own risk.

# Content

- 1. Introduction.....1**
- 2. Building Regulations Part L 2019 .....3**
  - 2.1 Regulation 8 Part (a) .....3
  - 2.2 Regulation 8 Part (b) .....3
  - 2.3 Regulation 8 Part (c) .....3
  - 2.4 Regulation 8 Parts (d & e).....4
  - 2.5 Regulation 8 Parts (f) .....4
  - 2.6 Requirements for Common Areas .....4
- 3. Building Regulations Part L 2017 (Building Other than Dwellings) .....6**
  - 3.1 Regulation L5 Parts (a) .....6
  - 3.2 Regulation L5 Parts (b) .....6
  - 3.3 Regulation L5 Parts (c) .....6
  - 3.4 Regulation L5 Parts (d) .....7
  - 3.5 Regulation L5 Parts (e) .....7
  - 3.6 Regulation L5 Parts (f) .....8
  - 3.7 Regulation L5 Parts (g) .....8
  - 3.8 Regulation L5 Parts (h) .....8
  - 3.9 Regulation L5 Parts (i) .....8
- 4. Building Fabric.....9**
  - 4.1 Elemental U-Values .....9
  - 4.2 Air Permeability .....9
  - 4.3 Thermal Bridging.....10
- 5. Heat Sources & Renewable Energy Options & Proposals .....11**
  - 5.1 Option 1 – District Heating .....11
  - 5.2 Option 2 – Individual Plant with Exhaust Air Heat Pumps .....12
  - 5.3 Option 3 – Electric Heaters, Hot Water Heat Pumps, Heat Recovery Ventilation & PV Panels .....12
  - 5.4 Apartment Corridors/Landlord Areas .....13
- 6. Heat Sources & Renewable Energy Options – Amenity Space .....14**
- 7. Proposed Solutions.....15**
  - 7.1 Apartments.....15
  - 7.2 Amenity Space .....15
- 8. Microwave Telecommunication Channels.....16**

## 1. Introduction

Knockrabo Investments DAC intend to apply to An Bord Pleanála for permission for a Strategic Housing Development with a total application site area of c. 1.78 ha, on a site located at Knockrabo, Mount Anville Road, Goatstown, Dublin 14.

The proposed development relates to Phase 2 of the development on the 'Knockrabo' lands. Phase 1 of 'Knockrabo' was granted under Dún Laoghaire-Rathdown County Council (DLRCC) Reg. Ref. D13A/0689/An Bord Pleanála (ABP) Ref. PL06D.243799 and DLRCC Reg. Ref. D16A/0821 (Phase 1) and DLRCC Reg. Ref. D16A/0960 (Phase 1A) and comprises a total of 125 no. units. The proposed development will consist of the amendment of the permitted 'Phase 2' residential development of 93 no. units, childcare facility and community/leisure uses (DLRCC Reg. Ref. D17A/1124) on a site of 2.75ha. The proposed development will provide for the reconfiguration and redesign of the approved residential development. The Knockrabo Way entrance road (constructed and unconstructed), the renovation of Cedar Mount House including childcare facility and community/leisure uses, the Coach House, Gate Lodge (West), the Gate House and all associated landscaping permitted under D17A/1124 which are outside the boundary of the current application are proposed to remain as previously granted.

The site is bounded to the south-east by Mount Anville Road; to the south by 'Mount Anville Lodge' and by the rear boundaries of 'Thendara' (a Protected Structure – RPS Ref. 812), 'The Garth' (a Protected Structure – RPS Ref. 819), 'Chimes', 'Hollywood House' (a Protected Structure – RPS Ref. 829); to the south-west by existing allotments; to the north by the reservation corridor for the Dublin Eastern By-Pass (DEBP); and to the east by the site of residential development 'Knockrabo'. There are 3 no. Protected Structures located in the overall 'Knockrabo' landholding, but which are outside the application boundary. These include 'Cedar Mount' (a Protected Structure - RPS Ref. 783), 'Knockrabo Gate Lodge (West)' (a Protected Structure - RPS Ref. 796), including Entrance Gates and Piers, and 'Knockrabo Gate Lodge (East)' (a Protected Structure – RPS 740) including Entrance Gates and Piers. For clarity no works are proposed to any Protected Structures as part of this proposed development.

The development, with a total gross internal area of c. 23,097.2 sqm, will consist of the construction of 227 no. residential units in 4 no. apartment blocks ranging in height from Part 2 – Part 8 storeys including semi-basement podium. The development will provide 76 no. 1 bed units, 145 no. 2 bed units and 6 no. 3 bed units as follows:

- **Block E** (c. 1015.3 sqm GIA) is a 5-storey including semi-basement podium apartment block comprising of 8 no. units (1 no. one bed unit and 7 no. 2 bed units).
- **Block F** (c. 8042.2 sqm GIA) is a Part 2 to Part 8 storeys including semi-basement podium apartment block comprising 84 no. units (53 no. 1 bed units and 31 no. 2 bed units).
- **Block G** (c. 8626.5 sqm GIA) is a Part 6 including semi-basement podium to Part 8 storey including semi-basement podium apartment block comprising of 82 no. units (37 no. 1 bed units, 40 no. 2 bed units and 5 no. 3 bed units).
- **Block H** (c. 5413.7 sqm GIA) is a Part 6 to Part 7 storey apartment block including semi-basement podium comprising 53 no. units (7 no. 1 bed units, 45 no. 2 bed units and 1 no. 3 bed unit).

Residential Tenant Amenities comprising c. 537.2 sqm are provided at Level 00 of Block G and H to serve all residential units within this application. Balconies/Wintergardens are provided on all elevations at all levels for the 4 no. apartment blocks, with (Private) Terraces provided at top floor levels and a communal Roof Terrace of c. 198 sqm to be provided on Block F. The development will also provide 178 no. car parking spaces, which comprises 125 no. residential podium parking spaces, 35 no. on-street parking

spaces, 16 no. visitor/drop off parking and 2 no. car sharing on-street parking spaces are provided; Provision of 389 no. private residential bicycle parking spaces and 130 no. visitor bicycle parking spaces; Provision of 12 no. motorcycle parking spaces.

All other ancillary site development works to facilitate construction, site services, piped infrastructure, 2 no. sub-stations, plant, public lighting, bin stores, bike stores, boundary treatments, provision of public, communal and private open space areas comprising hard and soft landscaping, site services all other associated site excavation, infrastructural and site development works above and below ground. The development will be served by the permitted access road 'Knockrabo Way' (DLRCC Reg. Ref. D13A/0689; ABP Ref. PL.06D.243799, DLRCC Reg. Ref. D16A/0821 and DLRCC Reg. Ref. D16A/0960). The application does not impact on the future access to the Reservation for the Dublin Eastern Bypass.

## 2. Building Regulations Part L 2019

Compliance with Building Regulations Part L 2011 is broken down into six distinct categories, known as Regulation 8; parts (a) to (f).

A summary of each of these parts as listed in Technical Guidance Document L 2011 is provided below together with a description of what is required to demonstrate compliance and suggested routes to meeting the required standards.

### 2.1 Regulation 8 Part (a)

The regulation requires that:

*Providing that the energy performance of the building is such as to limit the calculated primary energy consumption and related carbon dioxide (CO<sub>2</sub>) to that of a nearly zero energy building within the meaning of the Directive insofar as is reasonably*

Part (a) is the overarching compliance target which stipulates the required overall reduction in energy consumption and carbon emissions for new dwellings.

This requires that the energy consumption and carbon emissions of every dwelling is assessed using the DEAP software and that reductions of 70% in energy consumption and 65% in carbon emissions are achieved. The baseline against which this reduction is to be measured is considered to be a dwelling which is constructed to perfectly comply with the 2005 version of Building Regulations Part L.

The ratio of the energy consumed by the proposed dwelling to a similar dwelling constructed to 2005 energy efficiency standards is referred to as the “Energy Performance Co-efficient”

### 2.2 Regulation 8 Part (b)

The regulation requires that:

*Providing that, the nearly zero or very low amount of energy required is covered to a very significant extent by energy from renewable sources, including energy from renewable sources produced on-site or nearby;*

This requires that the all new dwellings are provided with a renewable energy source. The regulations state that 20% of the total energy consumed within the dwelling must be provided from renewable thermal sources (solar thermal, biomass, heat pumps) or renewable electrical sources (Photovoltaic, Micro-wind).

In practical terms, for a multiple unit development, this requirement is usually met by incorporating PV panels at roof level, incorporating air source heat pump technology or by adding an element of biomass or micro-CHP to a district heating scheme.

Where CHP is included, the renewable energy is considered to be the waste heat which is generated as a by-product of the electricity produced. Specific calculation methods are set out within TGD Part L 2019 which detail how compliance should be demonstrated.

### 2.3 Regulation 8 Part (c)

The regulation requires that:

*Limiting heat loss and, where appropriate, availing of heat gain through the fabric of the building;*

This requires that the fabric of the building is designed to minimise heat loss from the building and that the air permeability of the structure limits the unwanted passage of air into the building.



Typical compliant U-Values are as follows.

Pitched roof	0.16 W/m <sup>2</sup> K
Flat roof	0.20 W/m <sup>2</sup> K
Walls	0.18 W/m <sup>2</sup> K
Floor	0.18 W/m <sup>2</sup> K
Windows	1.4 W/m <sup>2</sup> K

The u-values of individual elements can be relaxed if required provided that compensatory measures are taken on other elements and that the overall area weighted u-value for the entire dwelling is the same as it would have been if all individual elements had complied.

The thermal bridging details of junctions in the envelope of the building (floor-wall; wall-window; wall-roof, etc) must also be designed and constructed in accordance with the guidance set out in Limiting Thermal Bridging and Air Infiltration – Acceptable Construction Details

Every dwelling must also be subjected to an air pressure test to determine the air tightness. All dwellings must achieve and **air tightness of less than 5m<sup>3</sup>/m<sup>2</sup>/hour** when tested at 50 Pascals. In multiple dwelling developments with repeating apartment types, testing can be conducted on a representative sample of units in accordance with Table 1.5.4.3 of TGD Part L 2019.

## 2.4 Regulation 8 Parts (d & e)

The regulation requires that:

*Providing and commissioning energy efficient space and water heating systems with efficient heat sources and effective controls;*

*Providing that all oil and gas fired boilers shall meet a minimum seasonal efficiency of 90%;*

These require that gas or oil-fired boilers are at least 90% efficient and that heating controls allow independent time control of the heating (2 zones for dwellings larger than 100m<sup>2</sup>) and hot water. Heating in each zone should also be controlled by room thermostats (in the case of heating) and cylinder stats (in the case of hot water).

## 2.5 Regulation 8 Parts (f)

The regulation requires that:

*Providing to the dwelling owner sufficient information about the building, the fixed building services and their maintenance requirements so that the building can be operated in such a manner as to use no more fuel and energy than is reasonable.*

This requires that information is provided to the dwelling owner which relates to the effective and efficient operation of the systems installed in that dwelling. Instructions on how to control the heating & hot water systems based on time and temperature requirements.

## 2.6 Requirements for Common Areas

Section 0.1.2.3 requires that:

*Where a new dwelling forms part of a larger building, the guidance in this document applies to the individual dwelling, and the relevant guidance in Technical Guidance Document L - Conservation of Fuel and Energy – Buildings other than dwellings applies to the non-dwelling parts of the building*

*such as common areas (including common areas of apartment blocks), and in the case of mixed-use developments, the commercial or retail space.*

This requires that the common areas of the apartment blocks are designed to meet Part L 2017 for Buildings Other Than Dwellings and will require that a portion of the energy demand for the common areas is met by a renewable energy source.

### 3. Building Regulations Part L 2017 (Building Other than Dwellings)

Compliance with Building Regulations Part L 2017 is broken down into seven distinct categories, known as Regulation L5 parts (a) to (i).

A summary of each of these parts as listed in Technical Guidance Document L 2017 is provided below together with a description of what is required to demonstrate compliance and suggested routes to meeting the required standards.

#### 3.1 Regulation L5 Parts (a)

The regulation requires that:

*(a) providing that the energy performance of the building is such as to limit the calculated primary energy consumption and related Carbon Dioxide (CO<sub>2</sub>) emissions to a Nearly Zero Energy Building level insofar as is reasonably practicable, when both energy consumption and Carbon Dioxide emissions are calculated using the Non-domestic Energy Assessment Procedure (NEAP) published by Sustainable Energy Authority of Ireland;*

Part (a) is the overarching compliance target which stipulates the required overall reduction in energy consumption and carbon emissions for new commercial buildings.

This requires that the energy consumption and carbon emissions of every building is assessed using the SBEM software and that the energy consumption and carbon emissions associated with the building being assessed are in line with the required standards.

#### 3.2 Regulation L5 Parts (b)

The regulation requires that:

*providing that, the nearly zero or very low amount of energy required is covered to a very significant extent by energy from renewable sources produced on-site or nearby.*

This requires that Renewable Energy Technologies are provided. This to be reflected by Renewable Energy Ratio (RER) which is the ratio of the primary energy from renewable energy sources to total primary energy as defined and calculated in NEAP. RER for commercial buildings was as follows

- Where the MPEPC of 1.0 and MPCPC of 1.15 is achieved an RER of 0.20
- Where an EPC of 0.9 and a CPC of 1.04 is achieved an RER of 0.10

#### 3.3 Regulation L5 Parts (c)

The regulation requires that:

*limiting the heat loss and, where appropriate, availing of the heat gains through the fabric of the building.*

This requires that the fabric of the building is designed to minimise heat loss from the building and that the air permeability of the structure limits the unwanted passage of air into the building.

Typical compliant U-Values are as follows.

Pitched roof	0.16 W/m <sup>2</sup> K
Flat roof	0.20 W/m <sup>2</sup> K
Walls	0.21 W/m <sup>2</sup> K
Floor	0.21 W/m <sup>2</sup> K
Windows	1.6 W/m <sup>2</sup> K

The u-values of individual elements can be relaxed if required provided that compensatory measures are taken on other elements and that the overall area weighted u-value for the entire building is the same as it would have been if all individual elements had complied.

The thermal bridging details of junctions in the envelope of the building (floor-wall; wall-window; wall-roof, etc) must also be designed and constructed in accordance with Acceptable Construction Details and/or certified details for all key junctions.

Buildings must also be subjected to an air pressure test to determine the air tightness and must achieve an air tightness of less than 5m<sup>3</sup>/m<sup>2</sup>/hour when tested at 50 Pascals.

### 3.4 Regulation L5 Parts (d)

The regulation requires that:

*providing and commissioning energy efficient space heating and cooling systems, heating and cooling equipment, water heating systems, and ventilation systems, with effective controls.*

This requires that heat- generators should be designed and installed so that they operate efficiently over the range of loading likely to be encountered. This means that gas or oil-fired boilers are at least 86% efficient for output less than 70kW and 93% efficient for output over 70kW. Space and water heating systems should be effectively controlled so as to limit energy use by these systems.

Additionally, buildings should be designed and constructed in such way that there is no requirement for excessive installed capacity of Air Conditioning and Mechanical Ventilation for cooling purposes and the ventilating and cooling systems installed are energy efficient and are capable of being controlled to achieve optimum energy efficiency.

### 3.5 Regulation L5 Parts (e)

The regulation requires that:

*ensuring that the building is appropriately designed to limit need for cooling and, where air-conditioning or mechanical ventilation is installed, that installed systems are energy efficient, appropriately sized and adequately controlled.*

This requires that the glazed elements of the proposed building are design to limit solar gain to acceptable levels. Design approaches that are often adopted to address this requirement include reducing total glazing areas, introducing internal or external shading devices or using specifically selected solar control glazing to reduce the solar gain.

### **3.6 Regulation L5 Parts (f)**

The regulation requires that:

*limiting the heat loss from pipes, ducts and vessels used for the transport or storage of heated water or air.*

This requires that hot water storage vessels, pipes and ducts associated with the provision of heating and hot water in a building should be insulated to limit heat loss, except where the heat flow through the wall of the pipe, duct or vessel is always useful in conditioning the surrounding space.

### **3.7 Regulation L5 Parts (g)**

The regulation requires that:

*limiting the heat gains by chilled water and refrigerant vessels, and by pipes and ducts that serve air conditioning systems.*

This requires that storage vessels for chilled water and refrigerant, and pipes and ducts that serve air-conditioning systems should be insulated to limit heat gain from the surrounding environment.

### **3.8 Regulation L5 Parts (h)**

The regulation requires that:

*providing energy efficient artificial lighting systems and adequate control of these systems.*

This requires that artificial lighting systems shall be designed and controlled so as to ensure the efficient use of energy for this purpose. Lighting controls should encourage the maximum use of daylight and help avoiding unnecessary artificial lighting.

### **3.9 Regulation L5 Parts (i)**

The regulation requires that:

*providing to the building owner or occupants sufficient information about the building, the fixed building services, controls and their maintenance requirements so that the building can be operated in such a manner as to use no more fuel and energy than is reasonable.*

This requires that information is provided to the dwelling owner which relates to the effective and efficient operation of the systems installed in that house. Instructions on how to control the heating & hot water systems based on time and temperature requirements.

## 4. Building Fabric

Before considering efficient building services or renewable energy systems, the form and fabric of a building must be assessed and optimised so as to reduce the energy demand for heating, lighting and ventilation. Target performance levels have been identified by the design team and are presented below.

### 4.1 Elemental U-Values

The U-Value of a building element is a measure of the amount of heat energy that will pass through the constituent element of the building envelope. Increasing the insulation levels in each element will reduce the heat lost during the heating season and this in turn will reduce the consumption of fuel and the associated carbon emissions and operating costs.

It is the intention of the design team to exceed the requirements of the building regulations. Target U-Values are identified below.

U-Values	Range of Target Values Proposed	Part L 2019 (Residential) Compliant Values	Part L 2017 (Commercial) Compliant Values
Floor	0.10 to 0.18 W/m <sup>2</sup> K	0.18W/m <sup>2</sup> K	0.21W/m <sup>2</sup> K
Roof (Flat)	0.12 to 0.20 W/m <sup>2</sup> K	0.20 W/m <sup>2</sup> K	0.20 W/m <sup>2</sup> K
Roof (Pitched)	0.10 to 0.16 W/m <sup>2</sup> K	0.16 W/m <sup>2</sup> K	0.16 W/m <sup>2</sup> K
Walls	0.10 to 0.18 W/m <sup>2</sup> K	0.18 W/m <sup>2</sup> K	0.21 W/m <sup>2</sup> K
Windows	0.9 to 1.4 W/m <sup>2</sup> K	1.4W/m <sup>2</sup> K	1.6W/m <sup>2</sup> K

### 4.2 Air Permeability

A major consideration in reducing the heat losses in a building is the air infiltration. This essentially relates to the ingress of cold outdoor air into the building and the corresponding displacement of the heated internal air. This incoming cold air must be heated if comfort conditions are to be maintained. In a traditionally constructed building, infiltration can account for 30 to 40 percent of the total heat loss, however construction standards continue to improve in this area.

With good design and strict on-site control of building techniques, infiltration losses can be significantly reduced, resulting in equivalent savings in energy consumption, emissions and running costs.

In order to ensure that a sufficient level of air tightness is achieved, air permeability testing will be specified in tender documents, with the responsibility being placed on the main contractor to carry out testing and achieve the targets identified in the tender documents.

A design air permeability target of **3 m<sup>3</sup>/m<sup>2</sup>/hr** has been identified for the apartments on the site.

The air permeability testing will be carried out in accordance with BS EN 13829:2001 'Determination of air permeability of buildings, fan pressurisation method' and CIBSE TM23: 2000 'Testing buildings for air leakage'

### 4.3 Thermal Bridging

Thermal bridges occur at junctions between planar elements of the building fabric and are typically defined as areas where heat can escape the building fabric due to a lack of continuity of the insulation in the adjoin elements.

Careful design and detailing of the manner in which insulation is installed at these junctions can reduce the rate at which the heat escapes. Standard good practice details are available and are known as Acceptable Construction Details (ACDs). Adherence to these details is known to reduce the rate at which heat is lost.

The rate at which heat is lost is quantified by the Thermal Bridging Factor of the dwelling and measured in W/m<sup>2</sup>K. The Thermal Bridging Factor is used in the overall dwelling Part L calculation, this value can be entered in three different ways:

0.15W/m <sup>2</sup> K	Used where the ACDs are not adhered to
0.08W/m <sup>2</sup> K	Used where the ACDs are fully adhered to
< 0.08 W/m <sup>2</sup> K	Used where the thermal details are thermally modelled and considered to perform better than the ACDs

It is intended that the ACDs will be adhered where suitable benchmarks exist and that thermal modelling will be carried out for any non-standard junction details within proposed development and that the resultant Thermal Bridging Factor will be less than 0.08W/m<sup>2</sup>K.

## 5. Heat Sources & Renewable Energy Options & Proposals

All new dwellings must meet overall energy performance levels (as defined by the Energy Performance Coefficient - EPC) and must have a portion of their annual energy demand provided by renewable energy sources.

The renewable energy source can be thermal energy such as solar thermal collection, biomass boilers or heat pumps or it can be electrical energy as generated by photovoltaic solar panels or wind turbines. The minimum renewable energy contributions defined in Part L 2019 Part (b) is 20% of the total energy consumption for the dwelling.

Two main fuel sources are generally available for developments of this nature, natural gas and electricity. Each present distinct options for compliance with the new standards. Solutions involving gas as the primary fuel source will typically include a solar technology such as PV panels to meet the renewable energy requirements while solutions relying on electricity will include heat pump technology.

The options presented in Sections 4.1 to 4.3 below set out three possible means of complying with Part L 2019 for the apartments. Each is based on the building fabric performance levels identified in Table 1 in Section 3.

The final selection and combination of technologies will most likely be selected from these options based on a more in-depth technical and financial appraisal of the technologies which will be carried out during detailed design.

### 5.1 Option 1 – District Heating

This approach would involve the generation of heat in a central location on the site and the distribution of this heat to each apartment via a network district heating pipework. The central plant used to generate the heat could include Air Source Heat Pumps, Combined Heat and Power (CHP) plant and high efficiency gas fired condensing boilers.

A CHP unit uses gas as its energy source to create electricity which can be utilised within the proposed development. This process of creating electricity results in the generation of “waste heat” which can then be used to meet a proportion of the heating and hot water demands of the housing development. Since the waste heat is captured it can be considered to be renewable energy and therefore contributes towards the overall 20% renewable energy requirement.

The Air Source Heat Pumps (ASHPs) utilise grid supplied electricity to extract thermal energy from a heat source, in this case, the external ambient air. While the electricity consumed is not considered renewable energy, the efficiency at which a heat pump operates allows a significant portion of the heat delivered to be considered as renewable energy. The amount of heat considered to be renewable is determined by the efficiency of the heat pump and the “primary energy conversion factor” for grid supplied electricity. Typically, approximately 40% to 50% of the heat supplied is considered to be renewable energy.

In order to meet the heating and hot water demands of the apartments in the proposed developments a district heating plant centre will be provided in each half of the development. Each plant centre will be capable of generating approximately 750kW to 1MW of heat energy. In this arrangement, the CHP would typically be sized to provide up to 30% of the total annual energy consumption, heat pumps would provide 30 to 40% and the remaining energy demand will be met by the gas fired boilers.

Heating pipework will be installed throughout the scheme to distribute the heat generated in the plant room throughout the apartment development, serving each apartment via a heat interface unit (HIU). The HIU will both control and meter the consumption of heat and hot water within each individual dwelling allowing occupants to set the times they need space heating and ensuring they are charged accordingly.



Heat Recovery Ventilation would then be provided in order meet the ventilation needs of the apartments. Air is extracted from wet rooms and supplied to living spaces via a central unit which contains supply and extract fans and a heat exchanger. This system recovers the heat from the warm air being extracted from the dwelling and uses the heat recovered to raise the temperature of the incoming air stream leading to improved overall efficiency.

## **5.2 Option 2 – Individual Plant with Exhaust Air Heat Pumps**

Exhaust Air heat pumps (EAHPs) operate in a very similar manner to the more conventional air source heat pumps and utilise grid supplied electricity to extract thermal energy from a heat source, in this case, the internal air within the apartment. The internal air is extracted from kitchens and wet rooms and is drawn into the heat pump via ductwork in the ceiling void. The heat pump extracts heat from this air before expelling it from the apartment.

While the electricity consumed is not renewable energy, the efficiency at which a heat pump operates allows a significant portion of the heat delivered to the dwelling be considered as renewable energy. The amount of heat considered to be renewable is determined by the efficiency of the heat pump and the “primary energy conversion factor” for grid supplied electricity. Typically, approximately 30% to 40% of the heat supplied is considered to be renewable energy.

There are a number of manufacturers offering products of this type and the certified seasonal efficiencies of some models can exceed 450% in heating mode and 170% to 190% in hot water mode. These efficiencies can deliver Part L 2019 compliance in most circumstances but in some instances may need supplementary PV panels in order to meet the required energy targets.

There is no requirement for a separate Mechanical Extract Ventilation (MEV) systems when an exhaust air heat pump is used as the heat pump draws the air from all wet rooms in the same manner as an MEV system would. The fan will run continuously to ensure that the minimum ventilation rates are maintained and the supply air to the dwelling is provided through trickle vents in each habitable room.

## **5.3 Option 3 – Electric Heaters, Hot Water Heat Pumps, Heat Recovery Ventilation & PV Panels**

This approach includes the provision of electric storage and/or convector heaters in the living & sleeping areas to meet all of the space heating requirements with electric towel rads provided in main bathrooms and en-suites.

The hot water demand is met by a hot water heat pump which utilise grid supplied electricity to extract thermal energy from a heat source in a similar manner to an Exhaust Air Heat Pump. The heat pump is ducted directly to the external façade through insulated supply & exhaust ductwork and uses external air for the hot water needs. It can use up to 3 times less electricity than direct acting water heaters and produces renewable energy to aid Part L compliance.

Heat Recovery Ventilation would then be provided in order meet the ventilation needs of the apartments. Air is extracted from wet rooms and supplied to living spaces via a central unit which contains supply and extract fans and a heat exchanger. This system recovers the heat from the warm air being extracted from the dwelling and uses the heat recovered to raise the temperature of the incoming air stream leading to improved overall efficiency.

PV panels are also then needed to improve the overall renewable energy contribution and improve the overall energy performance of the dwellings. Generally, 1 or 2 PV panels will be required for each apartment.

## **5.4 Apartment Corridors/Landlord Areas**

In accordance with the requirements of Part L 2019, the common areas within the apartment blocks are required to meet the requirements of Part L 2017 for “Buildings Other Than Dwellings”. Under Part L 2017, a portion (10% to 20%) of the energy demand of the common areas must be met by a renewable energy source. The energy demand within these spaces will be exclusively provided by electrical energy (lighting, space heating & lifts etc) so a photovoltaic array would be best suited to meet this renewable energy demand.

## 6. Heat Sources & Renewable Energy Options – Amenity Space

All new commercial buildings (Buildings Other Than Dwellings) must meet the overall energy performance standards and have a portion of their annual energy demand provided by renewable energy sources as set out in Part L 2017. This can be thermal energy such as **solar thermal collection**, **biomass boilers** or **heat pumps** or it can be electrical energy as generated by **photovoltaic solar panels** or **wind turbines**.

The minimum renewable energy contributions for a development of this nature is defined in Part L 2017 L5 Part (b) and is measured by the Renewable Energy Ratio (RER). This is the ratio of the primary energy from renewable energy sources to total primary energy demands of the building. Depending on the overall performance of the building, as measured by the EPC and CPC the required renewable energy contribution is either 20% or 10%

In order to determine the most efficient and effective means of complying with the requirements of Part L 2017 Part (b) a detailed assessment of the various renewable energy systems available will be conducted during the design stage using the SBEM calculation methodology.

There is a wide variety of possible solutions for heating, cooling and ventilation of non-domestic buildings which can be tailored to suit the proposed uses of the spaces and to meet the occupancy needs. Some spaces may require mechanical ventilations systems or comfort cooling to meet the required internal comforts levels, while others may simply need heating and natural ventilation. Hot water demands in non-domestic buildings also vary considerably depending on building use.

As part of the detailed design process, an SBEM analysis will be carried out to assess the proposed design solutions for compliance with the requirements of Part L 2017. Typical design solutions that will be assessed will include the following:

- Water based heating systems incorporating air source heat pumps or condensing gas boilers
- Natural ventilation where possible
- Mechanical ventilation systems incorporating heat recovery and/or heat pump technology
- Comfort cooling where required with inverter driven, R32 air conditioning technology
- LED lighting with occupancy and daylight controls
- Solar renewable energy systems (photovoltaic or solar thermal) if required to meet renewable contribution energy targets

## 7. Proposed Solutions

The preceding sections of this report set out the regulatory requirements with which the scheme will have to comply while identifying a number of technologies and design approaches that may be utilised to achieve compliance.

The building fabric standards and the technology solutions discussed will all be assessed in greater detail during the detailed design stage of the project. A cost benefit analysis of all these available solutions will be carried out to determine the correct balance between an efficient building envelope and the most appropriate combination of technology and renewable energy systems.

The proposed approach to achieving Part L Compliance will be based on a combination of the solutions below once a detailed analysis has been completed at detailed design stage. A final decision will be made once capital costs, renewable targets and regulation compliance have all been compared to find the most appropriate solution.

### 7.1 Apartments

The most likely overall solution that will be implemented will include the following measures:

- Exceed minimum U-Value standards by 20% to 30%,
- Achieve air tightness standards of  $3\text{m}^3/\text{m}^2/\text{hr}$
- Ensure thermal bridging details are designed to achieve thermal bridging factors of  $0.08\text{W}/\text{m}^2\text{K}$  or less.
- Provide an appropriate combination of technologies to ensure energy consumption is in line with Part L 2019 requirements. This will either include a centralised/district heating system or individual plant in each apartment (exhaust air heat pumps or electric heaters and hot water heat pumps).
- Install centralised mechanical ventilation systems to ensure adequate ventilation rates are achieved in the dwelling which maximising the benefits of the airtight construction

### 7.2 Amenity Space

The most likely overall solution that will be implemented will include the following measures

- Exceed minimum U-Value standards
- Achieve air tightness standards of  $5\text{m}^3/\text{m}^2/\text{hr}$
- Provide an air source heat pump to meet Part L renewable contribution requirements

## **8. Microwave Telecommunication Channels.**

We have reviewed the proposed development at Knockrobo and consider that the height and scale being sought for this new development will not have an impact on any current microwave telecommunication channels.

If however, a microwave link is found to be effected by this new development, during the construction stage of this project, mitigation will be employed by engaging with the telecommunication company and organising the re-alignment of their microwave links to a new hop site.

# UK and Ireland Office Locations



